

September 20, 2022

For Immediate Release

Investment Corporation

Canadian Solar Infrastructure Fund, Inc.

Representative: Hiroshi Yanagisawa  
Executive Officer  
(Securities Code: 9284)

Asset Manager

Canadian Solar Asset Management K.K.

Representative: Hiroshi Yanagisawa  
CEO & Representative Director  
Inquiries: Keiichi Yoshida  
Chief Financial Officer  
TEL: +81-3-6279-0311

**Notice concerning the Impact of the Typhoon (14<sup>th</sup>, named “Nanmadol”)**

We would like to express our deepest condolences to all those affected by the typhoon “Nanmadol” passed the Kyushu, Chugoku and Tohoku region for September 17 to 20, 2022 and our wishes for the earliest possible recovery.

Canadian Solar Infrastructure Fund, Inc. (hereinafter referred to as “CSIF”) announces that it has conducted a review of the impact upon power generation facilities in connection with the typhoon.

According to the report by Canadian Solar O&M Japan K.K., which is the O&M operator for the CSIF, S-02CS Isa-shi Power Plant, S-03CS Kasama-shi Power Plant, S-04CS Isa-shi Dai-ni Power Plant, S-05CS Yusui-cho Power Plant, S-06CS Isa-shi Dai-san Power Plant and S-08CS Hiji-machi Power Plant, all owned by CSIF, experienced temporary power outages due to grid power outages, but have resumed power generation as of 10:00 today. Similarly, the S-01CS Shibushi-shi Power Plant continues to experience power outages due to grid outages, but it is expected to resume power generation after the grid is restored. At S-13CS Mashiki-machi Power Plant, 3 PCS units (approx. 2MW) have stopped power generation due to the failure of some parts, and it is expected to take one to two weeks to restore the plant by replacing the parts. S-24 CS-Hiji-machi Dai-ni Power Plant has stopped power generation in some sections due to fallen trees on the power lines on the premises. 20 PCS units (approx. 20MW) out of the total 44 PCS units at the plant have stopped power generation, but 9 PCS units (approx. 9MW) of is expected to resume after the fallen tree is removed by the end of today. It is expected to take several weeks to restore power generation at the remaining 11 PCS units (approx. 11 MW) due to a broken wire sheath caused by a fallen tree.

CSIF will continue to monitor and review its portfolio, and additional disclosure will be made should there be any material developments.



In principle, insurance claims can be filed for any suspension of power generation at these power plants and lost rent revenue is limited, the impact on financial results is negligible.

End

URL of CSIF: <https://www.canadiansolarinfra.com/en/>